



Appliances properties: Olsberg GmbH - Olsberg - Alegre PowerBloc Compact - 41/627

Master data

Date of entry	Jul 21, 2017
Manufacturer	Olsberg GmbH - Olsberg
Model	Alegre PowerBloc Compact
Product code	41/627
Nominal heat output [kW]	5
Declared nominal space heating output [kW]	5
Continuous burning appliance	—
Type test standard	DIN EN 13240
Year of testing	2017
Test laboratory	Feuerstättenprüfstelle Kahl GmbH
Number of test laboratory	28
Number of test report	FK 40 17 497



Flue gas values

	Wood	Coal
Flue gas mass flow [g/s]	4.2	4.48
Flue gas mass flow [g/s]	273	341
Necessary flue draught [Pa]	12	12

Further important characteristics of the appliance

Suitability for installation to a shared flue¹⁾



Connectivity to the central heating system



General technical approval for room sealed operation



¹⁾ For unsealed operation it is possible to install the appliances to a shared flue system (please see installation manual).

On behalf of the manufacturer, the HKI Industrieverband e.V. hereby confirms compliance with the respective requirements* in accordance with 1.BImSchV. The type test report of the fireplace has been submitted to the HKI Industrieverband e.V.

* A green check mark with a „1“ indicates that the requirements of the 1st BImSchV are fulfilled, a green check mark with a „2“ indicates that the 2nd level of the 1st BImSchV is fulfilled. A yellow check mark shows that the transitional regulation of the 1st BImSchV is fulfilled and a red line means that the 1st BImSchV is not fulfilled.

- 
Stufe 2 Compliant with the requirements of the 2nd stage of the 1.BImSchV (only for Germany)
- 
Stufe 1 Compliant with the requirements of the 1st stage of the 1.BImSchV (only for Germany)
- 
2015 Compliant with the requirements of the Austrian Agreement pursuant to Art. 15a B-VG from 2015 (applies only to Austria)
- 
7★ Compliant with the requirements for the „Crédit d'impôt“ promotion in France, the fireplace complies with the classification 7* of the Flamme Verte Label
- 
6★ Compliant with the requirements for the „Crédit d'impôt“ promotion in France, the fireplace complies with the classification 6* of the Flamme Verte Label
- 
5★ Compliant with the requirements for the „Crédit d'impôt“ promotion in France, the fireplace complies with the classification 5* of the Flamme Verte Label
- 
★ Compliant with the requirements of the 1 star stage in Italy.
- 
★★ Compliant with the requirements of the 2 star stage in Italy.
- 
★★★ Compliant with the requirements of the 3 star stage in Italy.
- 
★★★★ Compliant with the requirements of the 4 star stage in Italy.
- 
★★★★★ Compliant with the requirements of the 5 star stage in Italy.
-  Fulfils the requirements
-  Complies with requirements of the transition ruling (1.BImSchV)
-  Requirements are not fulfilled
-  No information/unknown
-  No measuring values are available for this fuel, operation with this fuel is not permitted

No symbol means that there are no requirements.

Here you will find further information